



NORTH OLDHAM
FIRE PROTECTION DISTRICT

Fuel Dispensing Occupancies

Address-

Are the dispensing pumps protected from collision damage by a concrete island, posts, or guardrails?

-----Y -----N -----N/A

Is there a comprehensive safety plan in place including all storage of hazardous or dangerous goods must be available for viewing?

-----Y -----N -----N/A

Is there fuel dispensing procedures posted clearly in site? Vehicle can't be running, overflow prevention or spillage, if spillage occurs immediately apply absorbent to mediate the spill. No dispensing of fuel in close proximity of ignition sources; no dispensing of fuel into containers that are in a vehicle.

-----Y -----N -----N/A

Smoking is prohibited and signage must clearly posted in hazardous areas.

-----Y -----N -----N/A

Portable extinguishers must be:

At least 2 extinguishers locate at the pumping station.

-----Y -----N -----N/A

Mounted in a visible location, accessible, serviced/ inspected annually by a licensed technician.

-----Y -----N -----N/A

Full and functioning (no damage, corrosion, leaks malfunctioning parts or clogged nozzles).

-----Y -----N -----N/A

A minimum rating of 40-B-C

-----Y -----N -----N/A

There must be a shut off device to all dispensers and pumps at a remote location on the site and be shielded from any fire that may occur. This device must be identified and accessible to the attendants and emergency responders.

-----Y -----N -----N/A

There must be at least one attendant when the station is open unless it does not serve the general public. Attendants must have a clear unobstructed view of all dispensing pumps.

-----Y -----N -----N/A

Self service stations: Instructions on the operation of the dispensing pumps shall be posted; an attendant must have an unobstructed view of all the units at the same time and control console must be within 80 ft. A 2-way communication system must be provided.

-----Y -----N -----N/A

Discrepancies-

Notes-

Building Representative

Fire Inspector

Date:
